

BUILDING SAFETY CERTIFICATE

NO. 70/NBC

Date: 30/09/26

It is certified that the existing building **B.R.B MODEL SCHOOL** (Name of the building or premises) at **BAREILLY MATHURA STATE HIGHWAY KHASRA NO. 34, KHEDA BUJURG DISTRICT BADAUN UP** (address) is having block (s) Floor(s) as per details below:

Detail of Block(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	G + 3	Nil	Nil	Nil	Nil	Nil

The building is owned/occupied by **B.R.B MODEL SCHOOL** (name of the Institution) have complied with the Building safety requirements in accordance with National Building Code Rules, and verified by the officers concerned of **PWD** (Name of Department/ Govt.) on **29.09.2026** (date of inspection) in the presence of **MR SUBASH BATRA S/O LATE MR B.R BATRA** (name and address of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from **30.09.2026** for a period of **05 years** in accordance with rule and subject to compliance of the specific conditions as appended.

- 1- 6.00 m open area must be required around the building (NB Code Pt-3 Cl 8.3.1(a))
- 2- Provision of Earth quake Resistance drawing (as per Zone-III) must be required.
- 3- Stair width of building is not less than 1.50 m & rise 150 mm & tread 300 mm must be required (NB Code Pt-3 Cl 12.18)
- 4- Height of Parapet wall of building is not less than 1.00 m & not above than 1.20 (NB Code Pt-3 Cl 12.11)

Issued on **30.09.2026** at **Budaun** by

- Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.



Handwritten signature
06/10/2026

Signature with Seal:

30/9/2026
सहायक अभियन्ता

विभाग खण्ड-2, बरेली

बदायूँ

Name: *Mahendra Lal Singh*

Designation: *Assistant Engineer*

Name & Address of Department Office: *E.D.-2 PWD Budaun*